



MANHOLE REQUIREMENTS FOR SEWERS FOR ADOPTION 6TH EDITION - ADOPTIONS & DIVERSIONS

GENERAL REQUIREMENTS
 COPIES OF DELIVERY NOTES FOR CONCRETE AND PIPE BEDDING WILL BE REQUIRED INTERMITTENTLY AS THE JOB PROGRESSES. ALL OTHER COMPONENT UNITS MUST BE KITE-MARKED.

CHANNELS AND BENCHING
 ALL CHAMBERS WITH PIPE SIZES 150MM, 225MM, 300MM MUST HAVE SWEEP BENDS AND ALL BENCHING TO BE A MINIMUM 40MM THICK GRANULITHIC CONCRETE TROWELED TO A SMOOTH FINISH.

IRONWORK IN MANHOLES
 IF THE CHAMBER IS LESS THAN 3M DEEP WE REQUIRE DOUBLE ENCAPSULATED STEP RUNGS UNLESS OTHERWISE APPROVED. IF THE CHAMBER IS OVER 3M DEEP WE REQUIRE HOT DIPPED GALVANISED MILD STEEL LADDERS. THERE MUST BE 900MM BETWEEN LADDER AND BACK OF SHAFT. DEPTH IS MEASURED FROM FINISHED COVER LEVEL TO THE TOP OF THE BENCHING. THE MAXIMUM DISTANCE BETWEEN COVER LEVEL AND THE FIRST STEP MUST BE 675MM.

BRICKWORK
 MIN 2 MAX 4 COURSES UNDER FRAME AND MUST BE SOLID CLASS 8 ENGINEERING BRICKS OR CONCRETE SPACING RINGS NEATLY POINTED UP. ENGLISH BOND TO BE USED ON ALL BRICKWORK. SULPHATE RESISTING CEMENT MUST BE USED IN ALL LOCATIONS.

COVER AND FRAMES
 COVER SLAB OPENING, COVER AND FRAMES MUST BE 675 X 675 UNLESS OTHERWISE APPROVED. DN400 SHALL BE USED AT ALL LOCATIONS. ON SPINE ROADS MUST BE 1500M DEEP. ON RESIDENTIAL CUL-DE-SACS 1000MM MAY BE USED SUBJECT TO APPROVAL. FRAMES FOR MANHOLE COVERS SHOULD BE BEDDED IN A POLYESTER RESIN BEDDING MORTAR IN ALL SITUATIONS WHERE COVERS ARE SITED IN NRSWA ROAD CATEGORIES I, II OR III.

INFILL TYPE COVERS SHOULD NOT BE USED.
 IN BLOCK PAVED AREAS 150MM DEEP FRAMES MUST BE USED (IN ACCORDANCE WITH CL 2.8.6 SFA6 P.25)

LATERALS
 THEY SHOULD BE LAID TO THE SAME STANDARD AS PUBLIC SEWERS. THEY SHOULD HAVE NO CHANGES OF LINE OR GRADIENT BETWEEN THE SEWER AND THE DEMARCATION CHAMBER. THEY SHOULD HAVE AN ADOPTABLE MANHOLE AS THE DEMARCATION CHAMBER UNLESS THERE IS ONLY ON PROPERTY WHEN A PLASTIC CHAMBER TO BS7158 IS ALLOWED. LOCKABLE B125 AND A15 COVERS MAY BE ALLOWED IN CERTAIN LOCATIONS SUBJECT TO APPROVAL. THE DEMARCATION SHOULD BE INSIDE THE BOUNDARY OF THE PROPERTY, NO MORE THAN 1M INSIDE THE BOUNDARY, PREFERABLY IN THE DRIVEWAY AND NOT IN THE WHEEL TRACKS OF VEHICLES.

GENERAL NOTES

- LEVELS INDICATED IN BLOCKS ARE FINISHED FLOOR LEVELS WHICH ARE GENERALLY 150MM ABOVE GROUND LEVEL.
- ROADS FOOTPATHS AND PARKING BAYS WHICH FORM PART OF THE HIGHWAY TO BE ADOPTED UNDER SECTION 38 OF THE HIGHWAYS ACT 1980 SHALL COMPLY WITH THE RELEVANT COUNCIL HIGHWAY SPECIFICATION.
- SEWERS TO BE ADOPTED UNDER SECTION 104 OF THE WATER INDUSTRIES ACT 1991 SHALL COMPLY WITH THE WATER AUTHORITIES ASSOCIATION 'SEWERS FOR ADOPTION 6TH EDITION AND COMBINED ADDENDUM'.
- ALL PIPES TO BE USED IN ADOPTABLE SEWERS SHALL BE EITHER CLAYWARE TO BS 295-1:1991 AND BS 65:1991 (surface water pipes only), CONCRETE TO BS 5911-2:2002 OR UNPLASTICISED PVC PIPES TO BS 4660 BS EN1401-1:1998 WITH CLASS 3 BEDDING UNLESS OTHERWISE STATED. THE MINIMUM REQUIREMENT FOR PIPES TO BE USED IN ADOPTABLE SEWERS IS TO BE AS FOLLOWS:
 - 150MM DIA - CLASS 187 - MIN CRUSHING STRENGTH 28KN/M
 - LARGER THAN 300MM DIA - HIGH STRENGTH CONCRETE. WHERE COVER TO PIPES IS LESS THAN 1200MM UNDER CARRIAGEWAY OR VEHICULAR ACCESS AREAS THEY SHALL BE SURROUNDED WITH 150MM GRADE C20 CONCRETE. FLEXIBILITY OF JOINTS BEING MAINTAINED BY USING COMPRESSIBLE FIBREBOARD AT INTERVALS NOT EXCEEDING 5M.
- ALL EXISTING DRAINAGE INVERT LEVELS, DIAMETERS AND LOCATIONS ARE TO BE CHECKED BY THE CONTRACTOR PRIOR TO THE COMMENCEMENT OF ANY PROPOSED DRAINAGE WORK. ANY DIFFERENCE BETWEEN ACTUAL AND DRAWN DETAILS IS TO REPORTED IMMEDIATELY.
- POSITIONS OF EXISTING SERVICES/STAIRWAYS APPARATUS ADJACENT TO OR CROSSING PROPOSED SEWERS IS TO BE CHECKED BY THE CONTRACTOR PRIOR TO STARTING WORK.

MINIMUM DIMENSIONS FOR MANHOLES

Type	Size of largest pipe (Dm)	Min internal dimensions* length and width	Min clear opening size* Circular diameter	Min clear opening size* Rectangular length and width	Circular diameter
Manhole - 1.5m deep to soffit	150	750 x 675	1000	750 x 675	na*
	225	1200 x 675	1200	1200 x 675	
	300	1200 x 900	1200	1200 x 900	
- 1.5m deep to soffit	425	1200 x 1000	1200	675 x 675	600
	300	1200 x 1075	1200		
	375-450	1200 x 1025	1200		
Manhole shaft - - 3.0m deep to soffit of pipe	150mm	1000 x 800	1000	675 x 675	600
	225mm	1200 x 800	1200	675 x 675	600
	300mm	1200 x 800	1200	675 x 675	600

*Note: 1) Larger sizes may be required for manholes on banks or where there are junctions.
 2) May be reduced to 800 to 850 where required by highway traffic considerations, subject to a safe system of work being operated.
 3) The applicable depth is the working level.
 4) Minimum height of chamber in unadopted manhole 2m from benching to underside of reducing slab.
 5) All manhole covers must be marked and the position for the slab should be approximately 50mm.
 6) Where only one step or ladder, permanent or removable.
 7) The minimum size of any manhole opening in a pipe should be 1200mm x 675mm rectangular or 1200mm diameter.

The Contractor is to check and verify all building and site dimensions, levels and sewer invert levels at connection points before work starts. The Contractor is to comply in all respects with current Building Legislation, British Standard Specifications, Building Regulations, Construction (Design & Management) Regulations, Party Wall Act, etc. whether or not specifically stated on this drawing. This drawing must be read with and checked against any structural, geotechnical or other specialist documentation provided. This drawing is not intended to show details of foundations, ground conditions or ground contaminants. Each area of ground relied upon to support any structure depicted (including drainage) must be investigated by the Contractor. A suitable method of foundation should be provided allowing for existing ground conditions. Any suspect or fluid ground, contaminants on or within the ground, should be further investigated by a suitable expert. Any earthwork constructions shown indicate typical slopes for guidance only & should be further investigated by a suitable expert. Where existing trees / structures are to be retained they should be subject to a full specialist inspection for safety. All trees are to be planted so as to ensure they are a minimum of 5 metres from buildings. A suitable method of foundation is to be provided to accommodate the proposed tree planting.

Residential & Commercial Engineering Limited do not accept any responsibility for any losses (financial or otherwise) to any Client or third party arising out of the Clients (the Developer or Contractor but not limited thereto) non-compliance with aforementioned provisions.

© This drawing is the property of Residential & Commercial Engineering Limited and may not be copied or used for any purpose other than that for which it is supplied without the express written authority of Residential & Commercial Engineering Limited.

- GENERAL CONSTRUCTION NOTES**
- CONTRACTOR TO BE PRESENT DURING INSPECTIONS / COR TESTING.
 - ALL UTILITY EXISTING CROSSING POINTS ARE TO BE ADOPTED WITH HIGHWAYS CLEAR OF WORKS, SHOULD THEY DIFFER FROM THE POSITIONS SHOWN ON THE SET OUT PLANS.
 - ALL EXISTING DRAINAGE INVERT LEVELS & POSITIONS, TO BE CHECKED BY THE CONTRACTOR PRIOR TO COMMENCEMENT OF ANY PROPOSED DRAINAGE WORK.
 - ALL LEVELS, HIGHWAYS & DRAINAGE DETAILS SUBJECT TO CHANGE WITHOUT NOTICE. TECHNICAL APPROVAL VIA RELIANT APPROVAL AUTHORITIES.
 - ALL DRAINAGE SHALL COMPLY WITH BS501 1985 & THE BUILDING REGULATIONS PART G.
 - ALL EXISTING DRAINAGE SHALL BE 100MM DIAMETER UNLESS STATED TO BE 150MM DIAMETER TO ACCOMMODATE THE PROPOSED ADOPTION.
 - ALL MANHOLES - BE THEY PRIVATE OR ADOPTABLE - SHALL BE CONCRETE PROTECTION SHALL BE PROVIDED TO ALL LIFE LINES WITH COVER TO BE 150MM MINIMUM TO PROTECT FROM THE PUBLIC. CONCRETE PROTECTION SHALL BE PROVIDED TO ALL LIFE LINES WITH COVER TO BE 150MM MINIMUM TO PROTECT FROM THE PUBLIC.
 - WHERE A PIPE PASSES THROUGH A WALL AN OPENING IS TO BE PROVIDED TO THE PIPE. THE OPENING SHALL BE SURROUNDED BY A MINIMUM 100MM CONCRETE TO BE PROVIDED TO THE PIPE.
 - WHERE A PIPE IS INSTALLED WITHIN 1M OF A BUILDING IT IS TO BE FILLED WITH CONCRETE TO A LEVEL BELOW THE BUILDING EQUAL TO THE BUILDING FOUNDATION.
 - WHERE THE FORMATION OF A PIPE TRENCH IS ABOVE ORIGINAL GROUND LEVEL THE TRENCH SHALL BE MADE UP WITH WELL COMPACTED SOIL TO THE ORIGINAL GROUND LEVEL.
 - WHERE A DRIVEWAY FALLS TOWARDS A DRAINAGE IT SHALL BE PROTECTED BY A DRAINAGE CHAMBER TO PREVENT WATER DAMAGING THE BUILDING.
 - ALL DRAINAGE UNDER PROPOSED DRIVEWAYS MUST HAVE SUITABLE FALL PROTECTION MEASURES AT THE HIGHER LEVEL.
 - ALL DRAINAGE UNDER PROPOSED DRIVEWAYS MUST BE BACKFILLED WITH AN APPROVED GRADED GRANULAR MATERIAL.
 - ALL DRAINAGE MATERIALS MARKED WITH '1' TO BE ADDED WITH THE RELEVANT WATER CLOSER OF WORKS PRIOR TO ANY CHANGES TO THE MATERIAL SPECIFICATIONS.
 - POURED STONE VALUES, AGGREGATE SIZES, AGGREGATE ABRASSION VALUES, AND PROTECTION VALUES OF ALL SURFACES, COVERING MATERIALS, SHALL BE CHECKED BY THE CONTRACTOR PRIOR TO COMMENCEMENT OF WORKS.
 - A SCREEN IS TO BE FITTED OVER THE OUTFLOW PIPE TO THE LAST PIPING BEFORE IT ENTERS THE SEWER FOR ADOPTION 6TH EDITION. THE SCREEN SHALL BE MADE OF 150MM DIA. GALVANISED STEEL WITH 150MM DIA. HOLES. THE SCREEN SHALL BE INSTALLED AT THE POINT OF ENTRY TO THE SEWER. THE SCREEN SHALL BE INSTALLED AT THE POINT OF ENTRY TO THE SEWER. THE SCREEN SHALL BE INSTALLED AT THE POINT OF ENTRY TO THE SEWER.
 - CONTRACTOR SHALL PRIOR TO STARTING ANY WORKS CONTACT THE EXISTING SERVICE PROVIDERS TO OBTAIN THE NECESSARY RIGHTS OF DIVERSION AND TO OBTAIN THE NECESSARY RIGHTS OF DIVERSION AND TO OBTAIN THE NECESSARY RIGHTS OF DIVERSION.

A	Plots 1 & 2 foul drainage revised to use existing IC. SW control chamber & headwall revised at Clients request.	18.09.17	SM	#
Rev	Description	Date	Drawn	Check

Revisions:

Drawing Status:
 Subject to the following approvals:
 S11 - Subject to technical approval from the Local Authority (Highway)
 S12 - Subject to technical approval from the Local Authority (Water)
 S13 - Subject to technical approval from the Local Authority (Drainage)
 S14 - Subject to technical approval from the Local Authority (Highway)
 S15 - Subject to technical approval from the Local Authority (Water)
 S16 - Subject to technical approval from the Local Authority (Drainage)

Client:
 LIONCOURT HOMES

Project:
 TATENHILL LANE, BRANSTON

Title:
 ENGINEERING LAYOUT
 (1:500)

Job Number: RACE/LCH/TLB
Drawing No.: ENG_100
Revision: A

Scale: 1:500 @ A1
Date: JUNE '17
Drawn by: SM
Checked by: GJ

Contact us:
 Residential & Commercial Engineering Ltd.
 Unit 17, Lakeside Business Park, Walkmill Lane, Cannock, WS11 0XE.
 Tel : 01922 411552

ROAD AND LEVELS KEY

- Road Centre Line
- Carriageway High Point
- Carriageway Low Point
- Existing Ground Level
- Finished Floor Level
- Street Name Plate
- Part M Access
- Pedestrian Crossing

ADOPTABLE DRAINAGE KEY

FOUL WATER

- Manhole
- Pipe Line & Flow Direction
- Existing Line

SURFACE WATER

- Manhole
- Pipe Line & Flow Direction
- Existing Line

HIGHWAY DRAINAGE

- Gully
- Gully Drain / Gully Connection

PRELIMINARY
 SUBJECT TO CLIENT & TECHNICAL APPROVALS

ALL SEWERS IN ACCORDANCE WITH SEWER FOR ADOPTION 6TH EDITION & BUILDING REGULATIONS